

**Effective January 1, 2019, Env-Dw 702 through Env-Dw 706 read as follows:**

**PART Env-Dw 702 MICROBIOLOGICAL MCLs AND MCLGs**

Env-Dw 702.01 Applicability of Microbiological MCLs and MCLGs. The microbiological MCLs and MCLGs shall apply to all systems as defined in Env-Dw 701.05.

Env-Dw 702.02 Determination of Compliance with Microbiological MCLs and MCLGs.

- (a) Each O/O shall monitor for microbiological contaminants as specified in Env-Dw 707, Env-Dw 708, and Env-Dw 709.
- (b) Any of the following shall constitute an exceedance of the Escherichia coli (E. coli) MCL:
  - (1) The system has an E. coli-positive repeat sample following a total coliforms-positive routine sample;
  - (2) The system has an E. coli-positive or total coliforms-positive repeat sample following an E. coli-positive routine sample;
  - (3) The system fails to take all required repeat samples following an E. coli-positive routine sample; or
  - (4) The system fails to test for E. coli when any repeat sample tests positive for total coliform.
- (c) Upon completing all monitoring required for each sampling period, an O/O shall determine compliance with the E. coli MCL and the microbiological MCLGs and whether any coliform triggers have been exceeded, as specified in Env-Dw 707, Env-Dw 708, and Env-Dw 709.

Env-Dw 702.03 MCLs and MCLGs for Microbiological Contaminants. MCLs and MCLGs for microbiological contaminants shall be as stated in Table 702-1, below:

Table 702-1: Microbiological MCLs and MCLGs

<b>Microbiological Contaminant</b>	<b>MCL</b>	<b>MCLG</b>
Cryptosporidium	None established	Zero
<u>E. coli</u>	See 702.02(b)	Zero
<u>Giardia Lamblia</u>	None established	Zero
<u>Legionella</u>	None established	Zero
Viruses	None established	Zero

**PART Env-Dw 703 RADIONUCLIDE CONTAMINANT MCLs AND MCLGs**

Env-Dw 703.01 MCLs and MCLGs for Radionuclide Contaminants.

(a) For a community water system, the MCLs and MCLGs for radionuclide contaminants shall be as stated in Table 703-1, below:

Table 703-1: MCLs and MCLGs for Radionuclide Contaminants

<b>Radionuclide Contaminant</b>	<b>MCL</b>	<b>MCLG</b>
Compliance Gross Alpha	15 pCi/L	0 pCi/L
Radium 226 + 228	5 pCi/L	0 pCi/L
Uranium	30 µg/L	0 µg/L
Beta Particles	4 mrem/year	0 mrem/year

- (b) Compliance with radionuclide contaminant MCLs shall be:
  - (1) Calculated as specified in Env-Dw 710; and

(2) Based on the monitoring as specified in Env-Dw 707, Env-Dw 708, and Env-Dw 710.

(c) The combined radium-226 and radium-228 value shall be determined by the addition of the results of the analysis for radium-226 and the analysis for radium-228, provided both analyses are performed on samples collected on the same day.

Env-Dw 703.02 Radon Testing for New Water Supply Sources.

(a) Analysis for radon shall only be required as part of the approval process for new community or non-transient non-community water supply sources or a new source at an existing community or non-transient non-community water system pursuant to applicable provisions of Env-Dw 302, Env-Dw 305, Env-Dw 405, and Env-Dw 406.

(b) If the local legislative body of a political subdivision that is developing a new public water system or a new well for an existing public water system does not vote to approve funding for the radon test and the test is not fully funded by the state, the department shall not require the test to be performed by that political subdivision for that system or well.

Env-Dw 703.03 Beta Particles and Photon Radioactivity from Man-made Sources.

(a) The average annual concentration of beta particle and photon radioactivity from man-made radionuclides in drinking water provided by a community water system shall not produce an annual dose equivalent to the total body or any internal organ greater than 4 mrem/year.

(b) In accordance with 40 CFR 141.66(d)(2) except for the radionuclides listed in Table 703-2, below, the concentration of man-made radionuclides causing 4 millirem total body organ dose equivalents shall be calculated on the basis of an intake of 2 liters of drinking water per day using 168 hour data as listed in “Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” National Bureau of Standards Handbook 69 as amended August 1963, U.S. Department of Commerce.

(c) If 2 or more radionuclides are present, the sum of their annual dose equivalent to the total body or to any organ shall not exceed 4 mrem/year.

(d) The average annual concentrations assumed to produce a total body or organ dose of 4 mrem/year shall be as specified in Table 703-2, below:

Table 703-2: Average Annual Concentrations Assumed to Produce a Total Body or Organ Dose of 4 mrem/year

<b>Radionuclide</b>	<b>Critical Organ</b>	<b>Average Annual Concentration (pCi/L)</b>
Tritium	Total Body	20,000
Strontium 90	Bone Marrow	8

(e) Compliance shall be determined in accordance with Env-Dw 707, Env-Dw 708, and Env-Dw 710.

PART Env-Dw 704 REGULATED INORGANIC CHEMICAL CONTAMINANT MCLs AND MCLGs

Env-Dw 704.01 Applicability of MCLs and MCLGs for Health-Related Regulated Inorganic Chemical (IOC) Contaminants.

(a) Except as provided in (b) and (c), below, the MCLs and MCLGs for the health-related regulated inorganic chemical (IOC) contaminants specified in Env-Dw 704.02 shall apply to community water systems and non-transient non-community water systems.

(b) The MCLs and MCLGs for nitrate and nitrite specified in Env-Dw 704.02 shall apply to community water systems, non-transient non-community water systems, and transient non-community water systems.

(c) The MCL and MCLG for fluoride shall apply to all community water systems and only those non-transient non-community water systems that serve day care centers or schools with children under 9 years of age.

Env-Dw 704.02 MCLs and MCLGs for Health-Related Regulated IOC Contaminants. The MCLs and MCLGs for health-related regulated IOC contaminants shall be as listed in Table 704-1, below:

Table 704-1: IOC MCLs and MCLGs

IOC Contaminant	MCL (mg/L unless otherwise specified)	MCLG (mg/L unless otherwise specified)
Antimony	0.006	0.006
Arsenic	0.010	Zero
Asbestos	7 million fibers/L (longer than 10 µm)	7 million fibers/L (longer than 10 µm)
Barium	2	2
Beryllium	0.004	0.004
Cadmium	0.005	0.005
Chromium	0.1	0.1
Copper	See Env-Dw 704.03	1.3
Cyanide (as free Cyanide)	0.2	0.2
Fluoride (also see Env-Dw 706)	4.0	4.0
Lead	See Env-Dw 704.03	Zero
Mercury	0.002	0.002
Nitrate (as N)	10	10
Nitrite (as N)	1	1
Total Nitrate + Nitrite	10	10
Selenium	0.05	0.05
Thallium	0.002	0.0005

Env-Dw 704.03 Lead and Copper. The concentrations of lead and copper in drinking water shall be regulated as specified in Env-Dw 714.

#### PART Env-Dw 705 REGULATED ORGANIC CHEMICAL CONTAMINANT MCLs AND MCLGs

Env-Dw 705.01 MCLs and MCLGs for Health-Related Regulated Volatile Organic Chemical (VOC) Contaminants.

(a) The MCLs and MCLGs for the health-related regulated volatile organic chemical (VOC) contaminants specified in (b), below, shall apply to each community water system and each non-transient non-community water system that has not requested and received a waiver as provided in Env-Dw 712.19.

(b) The MCLs and MCLGs for health-related regulated VOC contaminants shall be as stated in Table 705-1, below:

Table 705-1: VOC MCLs and MCLGs

VOC Contaminant	MCL (mg/L)	MCLG (mg/L)
Benzene	0.005	Zero
Carbon tetrachloride	0.005	Zero
o-Dichlorobenzene (1,2-Dichlorobenzene)	0.6	0.6
para-Dichlorobenzene (1,4-Dichlorobenzene)	0.075	0.075
1,2-Dichloroethane	0.005	Zero
1,1-Dichloroethylene	0.007	0.007
cis-1,2-Dichloroethylene	0.07	0.07
trans-1,2-Dichloroethylene	0.1	0.1

VOC Contaminant	MCL (mg/L)	MCLG (mg/L)
Dichloromethane (Methylene chloride)	0.005	Zero
1,2-Dichloropropane	0.005	Zero
Ethylbenzene	0.7	0.7
Methyl tertiary-butyl ether (MtBE)	0.013	0.013
Monochlorobenzene (chlorobenzene)	0.1	0.1
Styrene	0.1	0.1
Tetrachloroethylene	0.005	Zero
Toluene	1	1
1,2,4- Trichlorobenzene	0.07	0.07
1,1,1-Trichloroethane	0.2	0.20
1,1,2-Trichloroethane	0.005	0.003
Trichloroethylene	0.005	Zero
Vinyl chloride	0.002	Zero
Xylene, Total	10	10

Env-Dw 705.02 MCLs and MCLGs for Health-Related Regulated Synthetic Organic Chemical (SOC) Contaminants.

(a) The MCLs and MCLGs for the health-related regulated synthetic organic chemical (SOC) contaminants specified in (b), below, shall apply to any community water system or non-transient non-community water system that has not requested and received a waiver as provided in Env-Dw 712.19.

(b) Subject to (c), below, the MCLs and MCLGs for SOC contaminants shall be as stated in Table 705-2, below:

Table 705-2: SOC Contaminant MCLs and MCLGs

SOC Contaminant	MCL (mg/L)	MCLG (mg/L)
Alachlor (Lasso)	0.002	Zero
Aldicarb (Temik)	0.003	0.001
Aldicarb sulfoxide	0.004	0.001
Aldicarb sulfone (aldoxycarb)	0.002	0.001
Atrazine (Atranex, Crisazine)	0.003	0.003
Carbofuran (Furadon, 4F)	0.04	0.04
Chlordane	0.002	Zero
Dalapon	0.2	0.2
Dibromochloropropane (DBCP)	0.0002	Zero
Di(2-ethylhexyl)adipate	0.4	0.4
Di(2-ethylhexyl)phthalate	0.006	Zero
Dinoseb	0.007	0.007
Diquat	0.02	0.02
Endothall	0.1	0.1
Endrin	0.002	0.002
Ethylene Dibromide (EDB)	0.00005	Zero
Glyphosate	0.7	0.7
Heptachlor	0.0004	Zero
Heptachlor Epoxide	0.0002	Zero
Hexachlorobenzene	0.001	Zero
Hexachlorocyclopentadiene	0.05	0.05
Lindane	0.0002	0.0002
Methoxychlor (DMDT, Martate)	0.04	0.04
Oxamyl (Vydate)	0.2	0.2

SOC Contaminant	MCL (mg/L)	MCLG (mg/L)
PAH - Benzo(a)pyrene	0.0002	Zero
Picloram	0.5	0.5
Polychlorinated Biphenyls (PCB)	0.0005	Zero
Pentachlorophenol	0.001	Zero
Simazine	0.004	0.004
Toxaphene	0.003	Zero
2,3,7,8 TCDD (Dioxin)	0.00000003	Zero
2,4,5 TP (Silvex)	0.05	0.05
2,4 D	0.07	0.07

(c) Analysis for the following contaminants shall be required only as part of the initial pumping test and water quality sampling program required by Env-Dw 302, Env-Dw 305, Env-Dw 404, or Env-Dw 406, as applicable, based on the identification of a potential source of one or more of the contaminants in the preliminary contamination source inventory completed pursuant to Env-Dw 302.12, Env-Dw 305.12, Env-Dw 404.01, or Env-Dw 406.14, as applicable:

- (1) Polychlorinated biphenyls (PCB);
- (2) Dalapon;
- (3) Endothall; and
- (4) 2,3,7,8 TCCD (Dioxin).

(d) Monitoring and compliance for SOC contaminants shall be as specified in Env-Dw 707, Env-Dw 708, and Env-Dw 712.

Env-Dw 705.03 MCLs and MCLGs for Health-Related Disinfection Byproducts.

(a) The MCLs and MCLGs for the health-related disinfection byproducts specified in (c) and (d), below, respectively, shall apply to each community water system, non-transient non-community water system, and transient non-community water system at which any chemical disinfectant is added to the water in any part of the drinking water treatment process.

- (b) Monitoring for disinfectant byproducts shall be as specified in Env-Dw 715.
- (c) The MCLs for disinfection byproducts shall be as specified in Table 705-3 below:

Table 705-3: Disinfection Byproducts

Contaminant	MCL (mg/L)
Total trihalomethanes (TTHM)	0.080
Haloacetic acids (five) (HAA5)	0.060
Bromate	0.010
Chlorite	1.0

- (d) The MCLGs for disinfection byproducts shall be as specified in Table 705-4, below:

Table 705-4: MCLGs for Disinfection Byproducts

Contaminant	MCLG (mg/L)
Bromodichloromethane	0
Bromoform	0
Bromate	0
Chlorite	0.8

Contaminant	MCLG (mg/L)
Chloroform	0.07
Dibromochloromethane	0.06
Dichloroacetic Acid	0
Monochloroacetic Acid	0.07
Trichloroacetic Acid	0.02

Env-Dw 705.04 Health-Related Regulated Residual Disinfectants.

(a) The maximum residual disinfection levels (MRDLs) specified in (c), below, shall apply to each community water system and non-transient non-community water system at which any chemical disinfectant is added to the water in any part of the drinking water treatment process.

(b) The chlorine dioxide MRDL specified in (c), below, shall apply to each public water system at which chlorine dioxide is used as a disinfectant or oxidant.

(c) The MRDLs and maximum residual disinfection level goals (MRDLGs) for disinfectant residuals shall be as specified in Table 705-5 below:

Table 705-5: MRDLs and MRDLGs

Contaminant	MRDL (mg/L)	MRDLG (mg/L)
Chlorine, as Cl <sub>2</sub>	4.0	4
Chloramines, as Cl <sub>2</sub>	4.0	4
Chlorine Dioxide, as ClO <sub>2</sub>	0.8	0.8

(d) Monitoring and compliance for residual disinfectants shall be as specified in Env-Dw 715.

Env-Dw 705.05 Special Treatment Chemicals.

(a) The MCLs and MCLGs for the treatment chemicals specified in (b), below, shall apply to community water systems and non-transient non-community water systems.

(b) The MCLs and MCLGs for treatment chemicals shall be as specified in Table 705-6, below:

Table 705-6: MCLs and MCLGs for Certain Treatment Chemicals

Contaminant	MCL	MCLG
Acrylamide	0.05% dose at 1 mg/L	Zero
Epichlorohydrin	0.01% dose at 20 mg/L	Zero

(c) Compliance with the MCLs and MCLGs in Table 705-6, above, shall be determined in accordance with Env-Dw 712.18.

PART Env-Dw 706 REGULATED SECONDARY CONTAMINANT MCLs (SMCLs)

Env-Dw 706.01 Regulated Secondary Contaminants SMCLs.

(a) This part shall apply to contaminants in drinking water at concentrations that primarily affect aesthetic qualities relating to the public acceptance of drinking water, known as secondary contaminants. At considerably higher concentrations of secondary contaminants, health implications may also exist.

(b) Subject to (c), below, the SMCLs for community water systems and non-transient non-community water systems shall be as stated in Table 706-1, below:

Table 706-1: Secondary Maximum Contaminant Levels

<b>Contaminant</b>	<b>SMCL</b>
Aluminum	0.05 - 0.2 mg/L
Chloride	250 mg/L
Color	15 color units
Copper	1.0 mg/L
Corrosivity	Non-corrosive
Fluoride	2.0 mg/L
Foaming Agents	0.5 mg/L
Iron	0.3 mg/L
Manganese	0.05 mg/L
Methyl tertiary-butyl ether (MtBE)	0.020 mg/L
Odor	3 threshold odor number
pH	6.5 - 8.5
Silver	0.1 mg/L
Sodium	250 mg/L
Sulfate	250 mg/L
Sulfide	0.05 mg/L
Total Dissolved Solids (TDS)	500 mg/L
Zinc	5 mg/L

(c) For aluminum, the SMCL based on color considerations shall be 0.05 mg/L and the SMCL based on treatment process considerations shall be 0.2 mg/L.

Env-Dw 706.02 Monitoring for Aesthetic-Related Regulated Contaminants.

(a) Monitoring for regulated secondary contaminants shall be as specified in Env-Dw 707, Env-Dw 708, and the applicable provision(s) of Env-Dw 711, Env-Dw 712, Env-Dw 713, and Env-Dw 714.

(b) Subject to (c), below, monitoring for the factors listed below shall be waived after initial testing required pursuant to Env-Dw 302, Env-Dw 305, or Env-Dw 406, as applicable:

- (1) Aluminum;
- (2) Color;
- (3) Corrosivity;
- (4) Foaming agents;
- (5) Odor;
- (6) Silver;
- (7) Sulfide; and
- (8) TDS.

(c) The system shall take samples for the appropriate factors listed in (b), above, based on:

- (1) Exceedances of the SMCLs in any of its active water supply sources; or
- (2) Customer complaints attributable to these factors.

**APPENDIX A - STATUTES/REGULATIONS IMPLEMENTED**

<b>Rule Section(s)</b>	<b>State Statute(s) Implemented</b>	<b>Federal Regulation(s) Implemented</b>
Env-Dw 702 (also see specific section below)	RSA 485:3, I	40 CFR 141.52; 40 CFR 141.63
Env-Dw 702.03	RSA 485:3, I	40 CFR 141.52; 40 CFR 141.63; 40 CFR 141.860
Env-Dw 702.04	RSA 485:3, I	40 CFR 141.52; 40 CFR 141.63
Env-Dw 703	RSA 485:3, I	40 CFR 141.55; 40 CFR 141.66
Env-Dw 704	RSA 485:3, I	40 CFR 141.51; 40 CFR 141.62
Env-Dw 705 (also see specific section below)	RSA 485:3, I	40 CFR 141.50; 40 CFR 141.53; 40 CFR 141.54; 40 CFR 141.61; 40 CFR 141.64; 40 CFR 141.65
Env-Dw 705.05	RSA 485:3, IV	40 CFR 141.111
Env-Dw 706	RSA 485:3, I(a), I(b)(1), II; RSA 485:16-a; 485:3, I	40 CFR 143.3; 40 CFR 141.64; 40 CFR 141.65